



Procurement Office  
675 West Main Street  
Rochester, NY 14611  
585-697-3625  
Fax: 585-697-7164  
WWW.ROCHESTERHOUSING.ORG

September 2, 2014

To: Contractors

RE: Rochester Housing Authority,  
**Fire Damage Restoration**

**140 West Ave.**

# 840

*2 pages including cover*

ADDENDUM #1

SEE ATTACHED

**Acknowledgement:**

I have received the above referenced Addendum # and have used it in the calculation/preparation of this bid.

\_\_\_\_\_  
Contractor

**THIS MUST BE SUBMITTED WITH YOUR BID SUBMISSION**  
**FAILURE TO DO SO MAY RENDER YOUR BID INVALID.**

**ROCHESTER HOUSING AUTHORITY  
FIRE DAMAGE RESTORATION DESIGN**

**HUNT 2285-019**

**ADDENDUM No. 1**

**September 2, 2014**

The following Addendum shall be considered a part of the contract documents prepared by HUNT ENGINEERS, ARCHITECTS & LAND SURVEYORS, P.C. dated **July 28, 2014**

**Drawings issued by this Addendum:**

**None**

**Project Manual Sections Issued by this Addendum:**

**None**

**Revisions to Drawings**

**Item AD1-A1 Refer to the Bill of Materials on A1.1**

Clarification: Mannington Edge Type TV - #933 Sandrift (not Edge Sculptural)

Clarification: Interface Cubic "Construction" #6395

**Item AD1-A2 Refer to General Construction Note "M"**

**AMEND** note to read:

"The contractor shall furnish 3M fire barrier water tight sealant 3000 WT, or equal, firestopping at the top & bottom of rated partitions. The same sealant shall be used on all penetrations of the floor and ceiling concrete deck - in particular the pipes in the kitchen and bathroom walls."

**Item AD1-A3 Refer to the General Construction Notes**

**ADD** note N to read:

"The contractor shall thoroughly clean the window frames, inspect screens for damage and lubricate the operating hardware as necessary to achieve proper function."

**Revisions to Project Manual**

**None**