



Procurement Office
675 West Main Street
Rochester, NY 14611
585-697-3625
Fax: 585-697-7164
WWW.ROCHESTERHOUSING.ORG

June 20, 2014

To: Contractors

RE: Rochester Housing Authority,
Fire Alarm Upgrades-Glenwood Community Center

ADDENDUM #1

See Attached

Acknowledgement:

I have received the above referenced Addendum #1 and have used it in the calculation/preparation of this bid.

Contractor

THIS MUST BE SUBMITTED WITH YOUR BID SUBMISSION
FAILURE TO DO SO MAY RENDER YOUR BID INVALID.

GLENWOOD FIRE ALARM
41 KESTREL ST.

ADDENDUM No. 1

Date: June 20, 2014

The following Addendum (Addenda) shall be considered a part of the contract documents prepared by HUNT ENGINEERS, ARCHITECTS & LAND SURVEYORS, P.C. dated **May 7, 2014**.

Based on questions from attendees at the Pre-Bid Walkthrough, the following clarifications and modifications to the project have been issued:

Item AD 1-1

The room labeled as a Conference Room is actually a storage room. Therefore, the contractor to provide a Smoke Detector Fixture in this room in place of the currently specified Strobe Fixture.

Item AD 1-2

Remove from the Contract Specifications the requirement in Section 28-31-00 for providing a printer. The Contractor will not be required to supply a printer.

Item AD 1-3

While recessed devices are preferred, in areas where there are no drop ceilings, surface mounted fixtures will be accepted.

Item AD 1-4

The Contractor shall provide a submittal of the installation detail for the wall-mounted devices proposed in the Meeting Room. The existing wall in this area is covered by a cloth and insulation material. It is expected that in all areas of work, the contractor shall provided installations that are neat, professional, and of good workmanship.