



Procurement Office
675 West Main Street
Rochester, NY 14611
585-697-3625
Fax: 585-697-7164
WWW.ROCHESTERHOUSING.ORG

July 20, 2015

To: Potential Bidders

RE: Rochester Housing Authority,
Kennedy Tower Bathroom Renovations

2 pages including cover

ADDENDUM #1

See Attached

Acknowledgement:

I have received the above referenced Addendum # 1 and have used it in the calculation/preparation of this bid.

Contractor

THIS MUST BE SUBMITTED WITH YOUR BID SUBMISSION
FAILURE TO DO SO MAY RENDER YOUR BID INVALID.

Addendum No. 1

**re Rochester Housing Authority
Kennedy Tower Bathroom Alterations
666 South Plymouth Avenue
Rochester, New York**

**from Konopka Architecture, PC
1501 East Avenue, Suite 1
Rochester, New York 14610
585.271.3480 / 585.271.3586 fax konopka@frontiernet.net**

date July 20, 2015

This Addendum consists of **one (1) page** including attachments, and forms part of the Contract Documents, and modifies the original Bidding Documents dated December 2014 as noted below

CHANGES TO DRAWINGS:

- A Drawing M1 - Unit Details, HVAC & Plumbing (Typical Bathroom) and
Drawing M2 - Unit Details, HVAC & Plumbing (Handicap Bathroom);
- 1 Equipment Lists, Tub-2, Delete and insert as follows;
PROVIDE BATHFITTERS TUB LINER AND ONE PIECE SURROUND LINER (OR EQUAL). 60" WIDE, WHITE, SMOOTH, ACCESSIBLE WITH GRAB BARS, DOUBLE CORNER SHELF, KOHLER K-7142-CP (OR EQUAL) TOE TAP RETROFIT KIT AND ALL ADDITIONAL HARDWARE FOR A COMPLETE TUB/SHOWER INSTALLATION.
- OR PROVIDE COMFORT WINDOW CO. INC. TUB LINER AND THREE PIECE SURROUND LINER (OR EQUAL). 60" WIDE, WHITE, SMOOTH, ACCESSIBLE WITH GRAB BARS, THREE SHELF CORNER CADDY, KOHLER K-7142-CP (OR EQUAL) TOE TAP RETROFIT KIT AND ALL ADDITIONAL HARDWARE FOR A COMPLETE TUB/SHOWER INSTALLATION.
- TUB LINER TO BE MINIMUM 0.240" THICK CO-EXTRUDED ACRYLIC/ABS MATERIAL. SURROUND TO BE MINIMUM 0.120" THICK CO-EXTRUDED ACRYLIC/ABS MATERIAL. TUB LINER TO BE CUSTOM FIT TO EACH TUB. LINER TO EXTEND TO CEILING. LINER, SURROUND AND CORNER SHELF BY SAME MANUFACTURER. MANUFACTURER LIFETIME WARRANTY ON TUB LINER AND SURROUND MATERIALS.

CHANGES TO SPECIFICATIONS:

- A None.

End of Addendum No. 1