



**Procurement Office**  
495 Upper Falls Blvd.  
Rochester, NY 14605  
Fax: 585-697-7164  
[WWW.ROCHESTERHOUSING.ORG](http://WWW.ROCHESTERHOUSING.ORG)

March 22, 2021

ADDENDUM #1

To: Potential Bidders

RE: Rochester Housing Authority

**373-375 Central Park**  
**Renovations**

**2 Pages including this cover sheet**

**Acknowledgement:**

**I have received the above referenced Addendum #1 and have used it in the calculation/preparation of this bid.**

\_\_\_\_\_  
Contractor

Without acknowledgement of this addendum your bid may be non-responsive.

## **Addendum #1 for 373-375 Central Park Renovations**

**Question:**

So, there's no abatement for this project?

**Answer:**

There isn't any abatement on the interior of the units. However, there is some minor caulk abatement around meters and cable lines plus the lead painted wood siding, wood trim and break metal trim under the vinyl siding. The lead will need to be removed and disposed of per section 6.3 on page 5 of Lu Engineers report and specification Section 02 83 13-1.

**Question:**

Where can we put the dumpster?

**Answer:**

It will have to go on the lawn or on the road in a parking spot. If there is a permit required, it will be the contractor's responsibility to apply for and pay for.