



Procurement Office
495 Upper Falls Blvd.
Rochester, NY 14605
Fax: 585-697-7164
WWW.ROCHESTERHOUSING.ORG

October 16, 2019

ADDENDUM #2

To: Potential Bidders

RE: Rochester Housing Authority

43-47 Bronson Court

2 Pages

SEE ATTACHED

Acknowledgement:

I have received the above referenced Addendum #2 and have used it in the calculation/preparation of this bid.

Contractor

Without acknowledgement of this addendum your bid may be non-responsive.

43-47 Bronson Court Abatement Addendum #2

Walk-Through Questions

October 2, 2019

1. Can the fire rated wall between units be removed in areas to allow set up of 1 work area rather than 2?

Answer: No

2. Can the mold affected gypsum fire wall between units be removed rather than treated?

Answer: No

3. Although the RBM report states that no drywall/joint compound debris was observed on the floor, should contractors be required to clean the floor throughout the fire damaged unit to verify that all asbestos fibers are cleaned up?

Answer: Yes