



Procurement Office
495 Upper Falls Blvd.
Rochester, NY 14605
Fax: 585-697-7164
WWW.ROCHESTERHOUSING.ORG

April 28, 2022

ADDENDUM #2

To: Potential Bidders

RE: Rochester Housing Authority

Bronson Court
Furnace and Hot Water Heater
Replacement
3Pages including this cover sheet

The Public Bid Opening will also be delayed by one day. The Public Bid Opening will be on Wednesday, May 25th at 11:00 am

Acknowledgement:

I have received the above referenced Addendum #2 and have used it in the calculation/preparation of this bid.

Contractor

BID ADDENDUM NO. 2

5/17/2022

Rochester Housing Authority

Bronson Court – Furnace and Hot Water Heater Replacement

2285-060

The following Addendum items shall be considered a part of the contract documents prepared by HUNT ENGINEERS, ARCHITECTS, LAND SURVEYORS & LANDSCAPE ARCHITECT, DPC. Bid Document date of 04/01/2022.

RFI addressed by this Addendum:

RFI 2-1:

Question:

Question: “Do you require a pressure gauge on both hot and cold-water supply piping?”

Answer: “No. Water pressure gauges are not part of this project.”

RFI 2-2:

Question:

Question: “Is there a circulator pump on the water heater? If so, the power source was never discussed at site visit.?”

Answer: “No - There is no water circulator associated with the hot water heater. To power the WH exhaust fan, RHA will provide a dedicated circuit breaker in the electrical panel for the contractor to use”

RFI 2-3:

Question:

Question: “For the concrete block under the tank can we use a Diversi-Tech pad 3" thick 32" X 32"?”

Answer: “Yes”

HUNT ENGINEERS, ARCHITECTS, LAND SURVEYORS & LANDSCAPE ARCHITECT, DPC

ROCHESTER OFFICE
4 COMMERCIAL STREET, SUITE 300
ROCHESTER, NY 14614
TELE: 585.327.7950

HORSEHEADS OFFICE
100 HUNT CENTER
HORSEHEADS, NY 14845
TELE: 607.358.1000

TOWANDA OFFICE
1 ELIZABETH STREET, SUITE 12
TOWANDA, PA 18848
TELE: 570.265.4868

HUNT-EAS.COM

RFI 2-4:

Question:

Question: "Why is the venting 3" pvc on the water heater when the manufacturer provides a new 2" outlet option "?

Answer: "The purchase of the RHA water heaters is out to bid at this time. The diameter of the PVC vent will depend on the (final) model that is purchased. The RHA spec for the AO Smith Power Vent model GPVL 40 allows for both a 2 or 3" vent. The contractor may use the 2" vent option as long as that is allowed by the WH manufacturers installation instructions".

End of Addendum 2

ACKNOWLEDGMENT OF RECEIPT BY:

LEGAL NAME OF BIDDER: _____

BY (Signature & Title): _____

DATE: _____

THIS PAGE SHALL BE ATTACHED TO AND SUBMITTED WITH THE BID PROPOSAL.