



Procurement Office
495 Upper Falls Blvd.
Rochester, NY 14605
Fax: 585-697-7164
WWW.ROCHESTERHOUSING.ORG

September 5, 2017

ADDENDUM 1

To: Potential Bidders

RE: Rochester Housing Authority,
Harriet Tubman Sidewalk Replacement

2 pages including cover

See Attached

Acknowledgement:

I have received the above referenced Addendum # 1 and have used it in the calculation/preparation of this bid.

Contractor

Addendum No. 1

**re Rochester Housing Authority
Harriet Tubman Estates
Sidewalk Replacement**

**from Marathon Engineering
39 Cascade Drive
Rochester, New York 14614
585.458-7770**

date September 5, 2017

This Addendum consists of one (1) page including attachments, and forms part of the Contract Documents, and modifies the original Bidding Documents dated August 2, 2017 as noted below.

CHANGES TO DRAWINGS:

A Drawing C3.0 - Detail 6 Concrete Sidewalk;

- 1 Add the following note; Provide Fibermesh 300 or equal in accordance with manufacturers recommendation as an additive to the concrete mix
or
Provide 6x6 W4.0/W4.0 welded wire mesh, support as necessary to provide 2" minimum concrete cover and installed per applicable standards.
Provide either in all concrete.**

CHANGES TO SPECIFICATIONS:

A None.

End of Addendum No. 1