



Procurement Office
495 Upper Falls Blvd.
Rochester, NY 14605
WWW.ROCHESTERHOUSING.ORG

December 15, 2022

ADDENDUM #1

To: Potential Bidders

RE: Rochester Housing Authority

Fire Unit Restoration-43 & 60 William Warfield Dr.
And posted at Avalon.

2 pages including this cover sheet

Acknowledgement:

I have received the above referenced Addendum #1 and have used it in the calculation/preparation of this bid.

Contractor

Without acknowledgement of this addendum your bid may be non-responsive.



12/15/22

Unit 43 & 60 WWD Fire Restoration-Walk-through Questions

Q: Are both of the different color tiles in the units tested for ACM's?

A: Per Environmental Engineer:

"I looked through the report and it looks like we sampled three separate tiles within the unit. Two of which were on the first floor (the positive ones beneath the cabinets and the negative ones everywhere else). The third tile was sampled on the second floor and was negative. With this info, I am confident that all materials have been sampled and the only one of concern is the tile beneath the old cabinetry."