



Procurement Office
495 Upper Falls Blvd.
Rochester, NY 14605
Fax: 585-697-7164
WWW.ROCHESTERHOUSING.ORG

June 30, 2026

ADDENDUM #1

To: Potential Bidders

RE: Rochester Housing Authority

1 and 1A Thomas Street Abatement

**There is one additional page included with this acknowledgement page.
It answers questions from the scheduled Walkthrough
Please review the additional sheet and include this signed acknowledgement with
your proposal.**

Acknowledgement:

**I have received the above referenced Addendum #1 and have used it in the
calculation/preparation of this bid.**

Contractor

Without acknowledgement of this addendum your bid may be non-responsive.

1 and 1A Thomas Street Abatement Contractor Questions and RHA Answers

Question: Please confirm whether the Contractor will be allowed to use a remote decontamination unit / remote hygiene facility that is not directly attached to the asbestos containment work area. Do the high risk of exposure to vandalism. During the night just prevent any potential damage or loss.
Since workers will be entering and exiting the work area daily, please clarify if this setup will be acceptable, provided that the Contractor follows all required NYS DOL procedures and obtains any required site-specific variance.

Answer: "Per Asbestos General Note No. 2, the contractor may apply for a site-specific variance that would allow for a remote decon. This variance shall be reviewed by LaBella prior to being submitted to the DOL (see specification 020800 - Asbestos Removal section 1.4.A.4). Any costs associated with the preparation and submittal of the variance shall be borne by the contractor."